

Flame Certificate
Mini Check Metallic
072321



Mini Check substrate, Flash, was tested and met the following flammability requirements:

FLAMMABILITY: ASTM-E84 Tunnel Test, Class A
 NFPA Life Safety Code 101, Class A
 CAN/ULC-S102, Passed all requirements

Contact hello@shopaino.com with any questions.